

NATIONAL TYPE EVALUATION PROGRAM

Certificate of Conformance for Weighing and Measuring Devices

For:

Weighing/Load Receiving Element

Load Cell Electronic

Models: VX2500L and VX5000L

n_{max}: 5 000 e_{min}: 1.0 lb (0.5 kg)

Capacity: 2 500 to 5 000 lb (1 250 to 2 500 kg)

Platform: 36" x 36" to 48" x 48"

Accuracy Class: III

*Submitted By: Contact Info. Updated: December 2010

Ohaus Corporation

7 Campus Drive, Suite 310 Parsippany, NJ 07054 Tel: 973-377-9000 Fax: 973-944-7177 Contact: Robert Hansen

Email: bob.hansen@ohaus.com
Web site: www.ohaus.com

Standard Features and Options

Construction:

• Painted Mild Steel

Options:

• Detachable Ramps and Locating Plates

Load Cells Used:

• Four Mettler Toledo Model 713 (Certificate of Conformance number 97- 072) or metrologically equivalent

Temperature Range: 10 °C to 40 °C (50 °F to 104 °F)

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of "NIST Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages. *Editorial changes, not affecting the type or metrological content, corrected this certificate.

Tim Tyson Chairman, NCWM, Inc. Randy Jennings

Chairman, National Type Evaluation Program Committee

Issued: December 28, 2010

1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.





Ohaus Corporation

Weighing/Load Receiving Element / VX2500L and VX5000L

Application: For use in general purpose weighing applications when interfaced with a NTEP approved and compatible indicating element.

Identification: The required information appears on a metal badge attached to the side of the floor scale.

Sealing: The floor scale weighing element is secured by a wire seal through 2 two tabs to secure the cover to the base of the junction box. The indicator is sealed according to the manufacturer's instructions for the particular indicator used.

Test Conditions: This certificate is issued based upon the following tests and upon information provided by the manufacturer. The emphasis of the evaluation was on device design, marking and operation. A 5 000 x 1 lb, 48 in x 48 in model VX5000L weighing element interfaced with the Mettler-Toledo Lynx Indicator (Certificate of Conformance Number 95-085) was submitted for evaluation. Several increasing/decreasing load and shift tests were performed. The scale was used for a period of more than 20 days with the criteria of Publication 14 for permanence tests of floor scales being met. The scale was again tested to the same procedure as the initial test.

Evaluated By: W. West (OH), T. Lucas (OH), A. McCoy (OH)


Type Evaluation Criteria Used: NIST, Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices, 2002. NCWM, Publication 14: Weighing Devices, 2002.

Conclusion: The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

Information Reviewed By: J. Truex (NCWM)

Example of Device:





Wire and Wire Crimp Seal (2 places)